



School District of Osceola County

ANNUAL COMPREHENSIVE SAFETY INSPECTION

School Year 07/01/14 to 06/30/15

Inspection Date: 05/07/15

Fish Number: 0853

School: New Dimensions High School

Address: 1900 Old Pleasant Hill Road

City: Kissimmee

State: Florida

Zip Code: 34759

Fire Code	RuleID	Priority	Bldg	Room	Est Cost	Type	Deficiency	Times Cited	Cor. Period
	1(e)8j	B	01	006	\$0.00	O	Ceiling tile needs replaced	1	60
	13(x)	B	01	006a	\$0.00	O	Storage needs removed	1	60
From rear stage ramp									
	101-7.1.10.2	C	02	0000	\$0.00	O	Storage and/or furniture in hallway must be removed	1	30
Table in hall outside of Media Center									
	8(c)1	C	02	Bathroom ms	\$100.00	M	Locking device must be replaced with one that allows free egress from inside.	1	30
Dead Bolts									
	101-10.3.1	F	04	406	\$0.00	O	Curtains must be labeled flame resistant from manufacturer.	1	30
Flags over windows									
	101-9.6.1.3	F	06	601	\$100.00	M	Fire alarm needs repair	1	30
Fire alarm dated 2013 battery dated 2007									
	101-9.6.1.3	F	99	Music	\$100.00	M	Fire alarm needs inspection and current tag	1	30
Fire alarm dated 2013 and Batteries dated 2010									

Inspector Signature: *Jennifer Hood* Date of Inspection: 5/7/15 Telephone Number: (407) 310-3617
 Inspector Signature: *Jennifer Hood* Print Name: Jennifer Hood
 Address: 817 Bill Beck Blvd, Kissimmee, Florida 34744
 For N. PK, KG-12 and Flokda School for the Deaf and Blind ONLY: Emergency Evacuation Drills Held Once Every Month Yes / No
 Approval of Reports by Board (including letter) Yes / No The District has complied with Section 1013.12(1)(c) F.S. Yes / No
 Signature of Facility Administrator attesting to Emergency Evacuation Drills and Review of Report Acknowledging awareness of discovered deficiencies:
 Administrator Signature: *Jennifer Hood* Date: 5-12-15