



School District of Osceola County

ANNUAL COMPREHENSIVE SAFETY INSPECTION

For School Year 07/01/20 to 06/30/21
 Inspection Date: 4/1/2021

Fish Number: 0853

School: New Dimensions High School

Address: 1900 Old Pleasant Hill Road

City: Kissimmee

State: Florida

Zip Code: 34759

Fire Code	RuleID	Priority	Bldg	Room	Est Cost	Type	Deficiency	Times Cited	Cor Period
	0081(11)(d)	C	00	0000	\$0.00	O	Emergency evacuation diagram needs to be posted	1	30
IN PROGRESS - (Interior Rooms) require a graphic diagram of primary and secondary evacuation routes shall be posted adjacent to the primary exit door from each student-occupied space. The diagram shall clearly indicate, by contrasting color and number, the primary and secondary route of evacuation. Exception: When an exit door from a self-contained classroom opens directly to the exterior.									
199	13(x)	B	100	006a	\$0.00	O	Storage needs removed	4	60
(Stage Ramps) - This is a continuous issue due to a lack of storage and sensitive equipment.									
	10(f)	E	100	116	\$0.00	O	Restroom accessories need repair/replaced.	0	30
Sinks are required to have soap and paper towels dispenser and supplies.									
804	17(b)	B	100	118	\$0.00	O	Extension cords are not approved for long term use - remove	0	60
(SRO's Office) Currently only has one electrical outlet available. Other options are being considered.									
	1(e)8h	E	200	201a	\$0.00	O	Light shield is missing - replace	1	30
	1(e)8h	E	200	mech	\$0.00	O	Light shield is missing - replace	1	30
Mechanical room between room 204 and 206									
	16(b)	B	300	Boys LR	\$0.00	O	Soap, towels, & toilet paper need to be provided	0	60
(Boys Locker Room) ADA stall needs paper towels.									
204	17(a)1	C	300	Girls LR	\$100.00	M	Emergency light needs to be repaired/replaced	0	30
(Girls Locker Room) In shower area - extmergency light combo needs replaced.									
	10(f)	E	300	Girls LR	\$0.00	O	Restroom accessories need repair/replaced.	1	30
(Girls Locker Room) Paper towels dispenser missing in ADA stall / sanitary bags must be provided in bins									
	None	N	400	0000	\$0.00	N	Deficiencies previously cited have been corrected	0	0
	17(b)	B	500	503	\$0.00	O	Cord running across door/ceiling/aisle must be removed	0	60
804	17(b)	B	500	503	\$0.00	O	Extension cords are not approved for long term use - remove	0	60

Inspector Signature: Jennifer Dymond Date of Inspection: 04/01/21 Telephone Number: 407-891-7758
 Reinspection Date: 05/17/21 Print Name: Jennifer Dymond Address: 817 Bill Beck Blvd., Kissimmee, Florida 34744